



## Public Water Supply District No. 2 Of Jefferson County

### New Service Specifications

1. These guidelines are for individual services, not for main extensions or new developments with multiple services. Developers with main extensions must follow the guidelines for those installations.
2. Specifications: The following specifications are minimum requirements for installation in P.W.S.D.#2. All materials used must meet or exceed the materials specified. P.W.S.D. #2 reserves the right to accept or reject alternate materials.
  - A. Type K copper or SDR9.
  - B. All brass construction saddle with tapered “cc” threads.
  - C. VB HH 172-15 or equivalent meter yoke.
  - D. Minimum of 20”x30” tall meter pit with 20” composite locking lid and frame.
  - E. All brass construction corporation stop with tapered “cc” threads.
  - F. Curb stop and valve box on customer side.
3. P.W.S.D. #2 personnel or our selected representative will do the actual tap of the main. District personnel are required to inspect the saddle, corporation, and meter setting before customer backfills. The district requires **forty-eight (48) hours of notice for all taps. It is unlawful for any person other than Public Water Supply District No. 2 personnel to obtain water from the new water main unless a tap and meter set has been paid for and installed.**
4. **There must be a permit obtained from Public Water Supply District No. 2 to have a meter installed on a fire hydrant for street cleaning, watering sod etc. Any violation will result in a tampering fee of \$750.00.**
5. P.W.S.D. #2 will work with customers on location of meter pits but reserves the right to make final determination of location.
6. Customer or customer representative is responsible for contacting Jefferson County Public Works Department for all street bores and all costs associated with the installation of the individual service including such things as street repair, yard work, rock removal, etc.
7. Fees: The fees of the district are:

A.	1” Tap fee	\$1500.00
	1” Security Deposit	\$100.00
B.	Security Deposit <b>1”</b> – owner/non-commercial	\$100.00
	Security Deposit <b>1”</b> – renter/commercial	\$150.00

**Security Deposits & tap fees increase for taps & meters larger than the normal 1” meter.**
8. Customer is responsible for all clean up or restoration work, including street repair, yard work, settling problems, reseeding, or planting. The customer or customer representative must call for location of other existing utilities **1-800-344-7483**. P.W.S.D. #2 will locate existing water mains.

9. Customer must secure all needed easements if water service is to be installed where there is no existing water easement. The customer is also responsible for permits for street crossings where the street must be saw cut or jack hammered and removed.
10. District requires plumbers who install the service to be bonded to the district. Bonds must be on file and must be current. Customers who have a contractor who is not currently on file must supply District with current bond before any work begins.
11. P.W.S.D. #2 reserves the right to refuse meter installation or to remove meter if any of the above requirements are not satisfied.
12. All commercial dwellings new and existing shall have an approved backflow prevention assembly as mandated by the Missouri Department of Natural Resources Rule 10CSR60-11.010. All devices need to be tested annually on their anniversary date and a copy of that report needs to be sent to Public Water Supply District No. 2. Failure to do this will result in termination of water service until the water user complies. Questions should be directed to our Office at 636-326-0200.
13. All residential homes that have an irrigation system installed will have to have a backflow device installed. This device needs to be tested upon installation, and annually on its anniversary date. Test reports need to be sent to Public Water Supply District No. 2. Failure to do this will result in termination of water service. Questions should be directed to our Office at 636-326-0200.
14. There will be no soldered connections on Public Water Supply District No. 2 side of the service line up to 2 ft. past the meter on the customers side of the service line. Service lines that run under streets and roads need to be in a casing made of PVC pipe.